

The 2022 Annual Drinking Water Quality Report for Hyrum City

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water sources have been determined to be from groundwater sources. Our water sources are the Main Spring, Box Elder Spring, Well #1, Cold Water Spring, Dry Hollow Spring, Well #3, and Well #4.

The Drinking Water Source Protection Plan for Hyrum City is available for your review. It contains information about source protection zones, potential contamination sources and management strategies to protect our drinking water. Our sources have been determined to have a low level of susceptibility from potential contamination from sources. We have also developed management strategies to further protect our sources from contamination. Please contact us if you have questions or concerns about our source protection plan.

There are many connections to our water distribution system. When connections are properly installed and maintained, the concerns are very minimal. However, unapproved and improper piping changes or connections can adversely affect not only the availability, but also the quality of the water. A cross connection may let polluted water or even chemicals mingle into the water supply system when not properly protected. This not only compromises the water quality but can also affect your health. So, what can you do? Do not make or allow improper connections at your homes. Even that unprotected garden hose lying in the puddle next to the driveway is a cross connection. The unprotected lawn sprinkler system after you have fertilized or sprayed is also a cross connection. When the cross connection is allowed to exist at your home, it will affect you and your family first. If you'd like to learn more about helping to protect the quality of our water, call us for further information about ways you can help.

This report shows our water quality and what it means to you, our customer.

If you have any questions about this report or concerning your water utility, please contact Kade Maughan at 435-245-6033. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on 1st and 3rd Thursday of each month at 6:30 p.m. at the City Hall.

Hyrum City routinely monitors for constituents in our drinking water in accordance with the Federal and Utah State laws. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2022. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Date- Because of required sampling time frames i.e. yearly, 3 years, 4 years and 6 years, sampling dates may seem outdated.

Waivers (W)- Because some chemicals are not used or stored in areas around drinking water sources, some water systems have been given waivers that exempt them from having to take certain chemical samples, these waivers are also tied to Drinking Water Source Protection Plans.

TEST RESULTS							
Contaminant	Violation Y/N	Level Detected ND/Low-High	Unit Measurement	MCLG	MCL	Date Sampled	Likely Source of Contamination
Microbiological Contaminants							
Total Coliform Bacteria	N	0	N/A	0	Presence of coliform bacteria in 5% of monthly samples	2022	Naturally present in the environment
Fecal coliform and <i>E.coli</i>	N	0	N/A	0	If a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or <i>E. coli</i> positive	2022	Human and animal fecal waste
Turbidity for Ground Water	Y	0-1.66	NTU	N/A	0.3	2019, 2022	Soil runoff
Inorganic Contaminants							
Arsenic	N	0-2.7	ppb	0	10	2019, 2022	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	N	0.028-0.068	ppm	2	2	2019, 2022	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Copper a. 90% results b. # of sites that exceed the AL	N	a. 0.106 b. 0	ppm	1.3	AL=1.3	2020	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems
Cyanide	N	0-2	ppb	200	200	2019, 2022	Discharge from steel/metal factories; discharge from plastic and fertilizer factories

Fluoride	N	0-0.183	ppm	4	4	2019, 2022	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead a. 90% results b. # of sites that exceed the AL	N	a. 2 b. 0	ppb	0	AL=15	2020	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen)	N	0.212-0.342	ppm	10	10	2022	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	N	0-0.7	ppb	50	50	2019, 2022	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	4.877-15.491	Ppm	500	None set by EPA	2019, 2022	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills.
Sulfate	N	5.017-36.746	ppm	1000	1000	2019, 2022	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills, runoff from cropland
TDS (Total Dissolved solids)	N	196-344	ppm	2000	2000	2019, 2022	Erosion of natural deposits
Disinfection By-products							
TTHM [Total trihalomethanes]	N	0.5-0.9	ppb	0	80	2022	By-product of drinking water disinfection
Chlorine	N	0.01-0.64	ppm	4	4	2019	Water additive used to control microbes
Radioactive Contaminants							
Alpha emitters	N	-0.7-1.5	pCi/l	0	15	2018, 2022	Erosion of natural deposits
Radium 228	N	-0.1-0.56	pCi/l	0	5	2018, 2022	Erosion of natural deposits

Microbiological Contaminants:

Turbidity. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hyrum City is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels.

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or manmade. Those constituents can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We at Hyrum City work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Hyrum City
60 West Main St.
Hyrum, UT 84319

January 30, 2023

Brandi Smith
CCR Compliance
Division of Drinking Water
P.O. Box 144830
Salt Lake City, Utah 84114-4830

Dear Ms. Smith:

Subject: Consumer Confidence Report for Hyrum City, #03008.

Enclosed is a copy of Hyrum City's Consumer Confidence Report. It contains the water quality information for our water system for the calendar year 2022 or the most recent sample data.

We have delivered this report to our customers by sending a notice of the availability of the report in the utility bills and sending it to those who request a copy. We will also make copies of the report available at the city office.

We have also made a good faith effort to reach those customers not directly billed by using posting the CCR on the Internet at this web address – hyrumcity.org

If you have any questions, please contact me at 435-245-6033.

Sincerely,

A handwritten signature in black ink, appearing to read 'K. Maughan', with a stylized flourish at the end.

Kade Maughan
Hyrum City